

## Generic PVT/Heat pump system for low energy single family house in Copenhagen (Denmark)

INFO Sheet D2-Denmark-SFH-heatdemand-7.1MWh-PVT-HP

|                       |   |
|-----------------------|---|
| Description:          | <i>Definition of a generic PVT/Heat pump system for low energy single family house in Denmark</i> |
| Date:                 | 30.04.2025  |
| Authors:              | Elsabet Nielsen, Simon Furbo, Janne Dragsted  |
| Contact:              | <a href="mailto:jadr@dtu.dk">jadr@dtu.dk</a>  |
| Download possible at: | <a href="https://task71.iea-shc.org/publications">https://task71.iea-shc.org/publications</a>     |
| DOI:                  | 10.18777/ieashc-task71-2026-0002  |

### Introduction

This document describes a generic PVT/heat pump system for low energy single family houses in Copenhagen, Denmark. The system covers the total domestic hot water consumption, the total space heating demand and a part of the electricity demand of the houses. The system is modelled with Polysun to calculate the electric energy needed to provide the required domestic hot water, space heating and household electricity (see info sheet D1 for description of the building, weather data and load profiles). The results in terms of electricity bought from the grid and sold to grid will be used as input for the LCA and LCoH calculation.

### Results

|  |            |
|--|------------|
| <b>Electricity supply</b>  |            |
| Electricity bought from the grid   | 3067 kWh/a |
| Electricity sold to the grid   | 4022 kWh/a |
| <b>Detailed results</b>  |            |
| Electric consumption of heat pump  | 1071 kWh/a |
| Electric consumption of solar collector loop pump  | 37.8 kWh/a |
| Electric consumption of circulation pump in heating loop                                       | 38.3 kWh/a |
| Operating hours of heat pump   | 1902 h     |
| Own electricity production which is used to meet the electricity demand of the heat generators | 206 kWh/a  |
| Own electricity production which is used to meet the electricity demand of the household       | 1374 kWh/a |


## Generic PVT/Heat pump system for low energy single family house in Copenhagen (Denmark)

INFO Sheet D2-Denmark-SFH-heatdemand-7.1MWh-PVT-HP

### Location and load (further details see Info sheet D DK)

|  |  |
|--|--|
| Location   | Copenhagen, Denmark  |
| Type of system   | PVT/heat pump system   |
| Weather data including<br>- hemispherical irradiance on horizontal surface<br>- beam irradiance on horizontal surface<br>- diffuse irradiance on horizontal surface<br>- ambient temperature | DRY Sjaelsmark, Denmark<br>$\Sigma G_{hem,hor} = 1038.1 \text{ kWh}/(\text{m}^2 \text{ a})$<br>$\Sigma G_{beam,hor} = 514.5 \text{ kWh}/(\text{m}^2 \text{ a})$<br>$\Sigma G_{diff,hor} = 523.6 \text{ kWh}/(\text{m}^2 \text{ a})$<br>$T_{amb,av} = 8.1 \text{ }^\circ\text{C}$ |
| Collector orientation<br>- Collector tilt angle to horizontal<br>- South-West deviation of collector<br>- ground reflectance<br>- resulting in hemispherical irradiance on collector surface | 45 °<br>South<br>0.2<br>$\Sigma G_{hem,tilt} = 1262.3 \text{ kWh}/(\text{m}^2 \text{ a})$  |
| Load information including<br>- heat demand for space heating<br>- heat demand for DHW<br>- setpoint tapping temperature<br>- inlet temperature of cold water                                | 3387 kWh/a /1/<br>1568 kWh/a /1/<br>50°C<br>10 °C seasonal $\pm 2 \text{ K}$ , see Appendix  |

### Hydraulic scheme of the system



## Generic PVT/Heat pump system for low energy single family house in Copenhagen (Denmark)

INFO Sheet D2-Denmark-SFH-heatdemand-7.1MWh-PVT-HP

### Description of the components required for simulation

|  |   |
|--|---|
| <b>Heat pump (METRO Delta)</b>                           |   |
| Capacity   | 3.5 kW  |
| COP and heating power according to EN14511, B0/W35°C     | 4.2 and 3.0 kW  |
| Electric power of heat pump during standby               | 10 W  |
| <b>Heat store (METRO THEM Model 160)</b>                 |   |
| heat store volume  | 138 l   |
| Tank material  | Steel with enamel   |
| Tank outer diameter without insulation                   | 0.4 m   |
| Tank outer height without insulation                     | 1.1 m   |
| Insulation of store                                      | PUR foam  |
| Thickness of insulation of store, top/sides/bottom       | 50 mm/30 mm/20 mm   |
| Heat loss coefficient                                    | 1.23 W/K  |
| Cabinet dimensions                                       | 0.46 m x 0.46 m x 1.40 m  |
| Heat loss coefficient                                    | 1.23 W/K  |
| Total mass of heat storage                               | 87 kg   |
| maximum heat store temperature                           | 70°C  |
| ambient temperature of heat store                        | 20°C  |
| <b>PVT panel (information based on gross area)</b>       |   |
| Electric efficiency                                      | $0.21 \times [1 - 0.0047 \times (T - 25)]$ [T: cell temperature, °C]  |
| Thermal efficiency: Maximum efficiency                   | 0.55  |
| Thermal efficiency: Linear heat loss coefficient         | 14.5 W/(m <sup>2</sup> K)   |
| Thermal efficiency: Wind dependent heat loss coefficient | $4.5 \times u$ W/(m <sup>2</sup> K) [u: wind speed, m/s]              |
| Thermal efficiency: Incidence angle modifier             | $K_{\theta} = 1 - \tan^p \left( \frac{\theta}{2} \right)$ , $p = 3.8$ |
| <b>Solar thermal controller and hydraulic piping</b>     |   |
| Total pipe length of collector loop                      | 20 m  |
| Outer diameter of collector loop pipe                    | 15 mm   |
| Volume flow rate of collector loop                       | 0.4 L/min per m <sup>2</sup> panel                                    |
| <b>Other components</b>                                  |   |
| Air vent   |   |
| One-way valve  |   |
| 2 circulation pumps                                      |   |

### References

/1/ info sheet D1 (building)